



NOTES:

1. Valves are not to be located in curb and gutter area.
2. Valve boxes are required at each valve location.
3. Valve boxes are to be in accordance with *Beaverton Standard Dwg 615* or as preapproved by the Utilities Engineer.
4. Maximum spacing for valves: 500 feet.
5. All valves to conform to *AWWA Standards*.
6. Use MJ gate valves for 8-inch and smaller lines, MJ butterfly valve for 10-inch and larger lines, or as specified by the *Engineering Design Manual Chapter 6*.



City Of Beaverton

ENGINEERING DEPARTMENT

UTILITIES ENGINEER
David A. Winship, P.E.

DATE
6 - 10 - 04

DRAWN BY
CDH - WD

DRAWING NO.
600

TYPICAL MINIMUM WATER VALVE LOCATION